CPWR KEY FINDINGS FROM RESEARCH



Overview

Rotary hammers and hammer drills are used extensively in commercial construction for drilling into concrete for tasks including rebar installation for structural upgrades and anchor bolt installation. A CPWR-supported research team has developed a test bench for standardized measurement of dust, noise, force and vibration during concrete drilling. In this experiment, the team tested three drill bits in different states of wear, measuring silica dust, noise, and productivity while drilling into concrete. Worn Drill Bits Decrease Worker Productivity – and Increase Silica Dust and Noise Hazards

The Effects of Bit Wear on Respirable Silica Dust, Noise and Productivity: A Hammer Drill Bench Study

Paul Carty, Michael R Cooper, Alan Barr, Richard L Neitzel, John Balmes, David Rempel. Annals of Work Exposures and Health, 2017.

Key Findings

The dull bit generated respirable silica dust levels 80%-114% higher than the sharp bit.

The sharp bit generated a mean noise level of 112.8 dBA, while the dull bit generated 114.4 dBA.

The sharp bit penetrated the concrete at 7.76 mm/s-1, while the dull bit did so at 10.16 mm/s-1.

Carbide tipped bits should be replaced when they show signs of wear in order to improve worker productivity and reduce worker exposure to dust and noise.

For more information, contact: Alan Barr: alan.barr@ucsf.edu

See abstract: http://bit.ly/2fZi3YH

©2017, CPWR – The Center for Construction Research and Training. All rights reserved. CPWR is the research, training, and service arm of North America's Building Trades Unions, and works to reduce or eliminate safety and health hazards construction workers face on the job. Production of this Key Finding was supported by Grant OH009762 from the National Institute for Occupational Safety and Health (NIOSH). The contents are solely the responsibility of the authors and do not necessarily represent the official views of NIOSH.



WWW.CPWR.COM